#### ADDENDUM NO. 5

# CITY OF HIALEAH 72 UNIT ELDERLY HOUSING 275 PALM AVE. HIALEAH, FLORIDA

January 8, 2013

## TO ALL CONCERNED

The original Contract Documents, for the Project entitled CITY OF HIALEAH – 72 Unit Elderly Housing, RAILINGS AND MISCELLANEOUS METALS BID NO. 2012/13-3230-00-023 is hereby amended as noted in this Addendum No. 5.

This **Addendum No. 5** consists of **1** Typed Pages, **0** Sketches, **0** Attachments and **0** Drawings. All other items and conditions of the original Contract Documents shall remain unchanged. This Addendum shall become a part of the Contract Documents.

Approved for issue:

Date: January 8, 2013

#### ACKNOWLEDGEMENT

Receipt of this **Addendum No. 5** shall be acknowledged in the space provided on the ADDENDUM RECEIPT FORM (ARF) (copy attached) now a part of the Contract Documents faxed immediately to City of Hialeah @ (305) 687-2642, and submitted with sealed bids.

### IN THE CONTRACT DOCUMENTS:

Response to RFI from Railko, Inc. dated January 3, 2013 & January 5, 2013:

Luis Azan - Project Manager

- 1) What are the center to center measurements for the hexagonal screen holes?

  The center to center measurement for the hexagonal holes in the screens in 1-7/8" (Inches).
- 2) Where are the locations of the corner and column guards? Page AS-002, Details 09 and 10.

  Corner guards are to be installed on the corner of the chases located on the following rooms: Meter room/Domestic Water Pump/Elevator machine Room/Trash-Recycle Room/Storage Room.

RAILINGS & MISCELLANEOUS METALS-BID #2012/13-3230-00-023

PAGE 1 OF 1 END OF ADDENDUM NO. 5

# ADDENDUM RECEIPT FORM

# CITY OF HIALEAH 72 UNIT ELDERLY HOUSING 275 PALM AVE HIALEAH, FLORIDA

CONTRACTOR'S NAME		
ADDRESS		
PHONE NO	FAX NO	
CONTACT NAME	SIGNATURE	
	E <b>DGES RECEIPT OF THE FOLLOW</b> OPY OF THIS FORM MUST BE FAXEI 42.	
ADDENDUM	<b>SIGNATURE</b>	DATE
ADDENDUM 5	<u>SIGNATURE</u>	<u>DATE</u>

RAILINGS & MISCELLANEOUS METALS-BID #2012/13-3230-00-023

ARF